

September 20, 2025

To,
The General Manager
BSE Limited
Phiroze Jeejeebhoy Towers
Dalal Street
Mumbai - 400 001

To,
Asst. Vice President,
National Stock Exchange of India Ltd.
Exchange Plaza, C-1, Block G, Bandra
Kurla Complex, Bandra (E),
Mumbai - 400 051

BSE Scrip Code: 516082
NSE Symbol: NRAIL

Subject: Intimation under Regulation 30 of the Securities and Exchange Board of India ("SEBI") (Listing Obligations and Disclosure Requirements) Regulations, 2015 ("SEBI Listing Regulations") - Fire at Unit I plant located at Vapi, Gujarat

Dear Sir/ Ma'am,

Pursuant to Regulation 30 read with Schedule III and other applicable provisions of the SEBI Listing Regulations, we regret to inform you that a fire broke out on Friday, September 19, 2025 at 6.15 p.m. at our Unit-I plant located at Plot No.169, Phase II, GIDC, Vapi - 396 195, Dist. Valsad, Gujarat. First fire was noticed in Electrical Transformer which spread to Electrical PCC room, VFDs, ACBs, LT and HT cables, etc.

The fire was controlled by using in-house firefighting systems and also fire tenders from GIDC Vapi. The Company has Industrial All Risk Insurance Policy and the claim has been lodged. The estimated monetary loss is approximately Rs. 4 crores and estimated production loss is approximately 2300 MT. The said plant is expected to be in operation in 7 days time.

This is for your information and records.

Thanking you,

Yours faithfully,
For N R Agarwal Industries Limited,

Pooja Daftary
Company Secretary & Compliance Officer